



MAGNUM MARKETING SERVICES

Redg. Address :- B/H. House NO.172, Opp Bhima Shankar Mandir, Desaiwad,
AT.Post - Tukwada, Via Udawada (R.S) -Valsad - 396185
info@magnumgroups.in | +91 9825500290 | www.magnumgroups.in

DATE: 04 October, 2023

MMS/Refill/23-24/19

To,
M/s. COAST GUARD PUBLIC SCHOOL
DAMAN

Sub. - CERTIFICATE FIRE EXTINGUISHERS

Respected Sir,

Please note that following fire extinguisher is Serviced got refilled and done with HPT Test in our workshop as per IS 15683, IS 2878 & now in good working condition.

SR. NO	EXTINGUISHER TYPE	QTY	REFILLING	HYDROSTATIC STRETCH TEST
1	ABC 6KG	16 NOS	DONE	DONE
2	CO ₂ 4.5KG	03 NOS	DONE	-

Refilled on
OCTOBER, 2023

Next due Date
OCTOBER 2024

Warranty of above-mentioned fire extinguishers is for one year (till next refilling due date) and needs to refill it again.

Thanks, and regards,
M/s MAGNUM MARKETING SERVICES





VERNI GASTECH PVT. LTD.

Mfg. & Supplier of All Kind of Industrial, Medical, High Purity,
Mixture & Calibration Gases & PESO approved Cyl. Test shop.

AN ISO 9001:2015

Factory : Plot No. A-144, Opp. Fire Station, G.I.D.C.,

Ankleshwar - 393 002, Dist. Bharuch, Gujarat.

Phone : 02646-220415, 224536, 99041 94000.

E-mail: info@vernigastech.com, Web : www.vernigastech.com

HYDROSTATIC STRETCH TEST REPORT

Certificate No. VGPL/23-24/B973

Date : 26/09/2023

PESO Licence No:-A/G/WC/GJ/GCT/24(G54574)

Client's Name & address:

M/S : MAGNUM MARKETING SERVICES

VAPI.

C/O. SAI SAMARTH INDUSTRIAL

Sr. No.	Cylinder No.	Original Test Date	Gas	Make	Specification	Testing Pressure (Kg/cm ²)	Working Pressure	Original Tare Weight (KG)	Actual Tare Weight	Diff. In (KG)	% Diff. in Org. Tare	Water Capacity in (Ltr.)	Test Date	Temporary Stretch in (C.C.)	Permanent Stretch in (C.C.)	% Diff. or Variation	Perm/Temp Stretch	Hydrostatics Stretch test	Cylinder Test Due On
1	26134	Jun-06	CO2	***	***	225	-	11.60	11.60	0.00	0.00	7.50	24-09-2023	43.0	0.30	0.70	OK	OK	Sep-28
2	1108	Oct-08	CO2	***	***	225	-	12.30	12.30	0.00	0.00	7.50	24-09-2023	41.0	0.50	1.22	OK	OK	Sep-28
3	33027	May-05	CO2	***	***	225	-	11.10	11.10	0.00	0.00	7.50	24-09-2023	39.0	0.30	0.77	OK	OK	Sep-28

N.B. FOR MORE DETAILS REFER RULE 35 OF GAS CYLINDER RULES (AMMENDED) 2018.

Tested By: J.N. Modi

Manager (Test Shop)



Page: 1 of 1